

# COVID-19 Safe Practices Walkthrough



<b>Date:</b>	10.21.20	
<b>District:</b>	Grants Cibola School district	
<b>School:</b>	San Rafael	
<b>District Signature</b>	<i>Runny San Jose</i>	
<b>Fire Marshal Signature</b>	<i>[Signature]</i>	
<b>Current Status</b>	<b>Use Drop</b>	
<b>Down</b>	<b>Safe Practice</b>	<b>Notes</b>
No response needed	Multi-ply cloth <b>masks</b> available and utilized by all staff and students, over the nose and mouth, secure under the chin, snug on face with no gaps	Extra disposable masks on hand? Nurse is keeping PPE in nurse room.
Response needed regarding 5 <sup>th</sup> and 6 <sup>th</sup> grade class room.	Classrooms and commons areas are set up for <b>6 feet social distancing and less than 50% student class size in place</b>	25 students are currently attending in person learning. 5 <sup>th</sup> and 6 <sup>th</sup> grade classrooms need adjustment. School in under the 50 % occupancy load for each class room.
No response needed.	If applicable, <b>cafeteria (or other congregate feeding area) is set up for 6 feet social distancing</b> and cohorts of students are not mixed	Cafeteria is not in used, students are being feed in class room.
No response needed.	<b>Hand sanitizer</b> that contains at least 60% alcohol is available across the school	70% hand sanitizer is available throughout the school. Wednesday is deep cleaning day.
No response needed.	School doors and windows are operable	Optimal air flow in place in each classroom? Doors and windows are operable and air can be felt in each class room
No response needed.	School ventilation systems are functional	What type of filtration is in place? Merv 8 filters were installed on October 22,2020 per Gregory Gallegos maintenance supervisor.
No response needed.	Evacuation Plan in place that maintains 6 feet social distancing	Students are being evacuated with verbal reminders to keep distance.