

COVID-19 Safe Practices Walkthrough



| | | |
|------------------------------------|---|---|
| Date: | 1/14/2021 | |
| District: | Hobbs | |
| School: | Broadmoor | |
| District Contact Name | TJ PARKS | District Signature: |
| Fire Marshal Signature | | |
| Current Status Use Drop Down | Safe Practice | Notes |
| Fully Implimented | Multi-ply cloth masks available and utilized by all staff and students, over the nose and mouth, secure under the chin, snug on face with no gaps | Masks - each student has been issued or will be issued a cloth reusable HMS Mask; Disposable masks will be provided to each classroom for those occurrences when cloth mask is unavailable or becomes soiled. |
| Fully Implimented | Classrooms and commons areas are set up for 6 feet social distancing and less than 50% student class size in place | Layout of each classroom allows for 6' of spacing between seats of nearest classmate |
| Fully Implimented | If applicable, cafeteria (or other congregate feeding area) is set up for 6 feet social distancing and cohorts of students are not mixed | Available seats are 6' apart. Seats facing the same direction. No seats face another seat. |
| Fully Implimented | Hand sanitizer that contains at least 60% alcohol is available across the school | Every classroom is equipped with a hand sanitizer dispenser. The supply of these dispensers are checked daily by classroom staff and custodial staff. Additionally, Classrooms with sinks have hand soap dispensers. The supply of these dispensers are checked daily by classroom staff and custodial staff. |
| Fully Implimented | School doors and windows are operable | All classrooms have been equipped with MERV 13 filters and will be changed every 60 days; Classrooms equipped with operable windows are allowed to open at the staffs discretion |
| Fully Implimented | School ventilation systems are functional and meet standard | All classrooms have been equipped with MERV 13 filters and will be changed every 60 days; Building Controls are maximizing the amount of fresh air into the classroom while maintaining the comfort level for learning to occur. Increased from 20% to 25% fresh air at a minimum. |

COVID-19 Safe Practices Walkthrough

| | | |
|-------------------|--|---|
| Fully Implimented | Evacuation Plan in place that maintains 6 feet social distancing | Dismissal and Transitions - Maintain 6' of distance between persons. Emergency paths are established and gathering areas facilitate 6' of each student group. |
| Fully Implimented | Isolation rooms for symptomatic individuals in place | The isolation room is maintained and is located within the main office area and next to Principal's office. |