

COVID-19 Safe Practices Walkthrough Form

Date:	2/11/2021	
District:	Raton Public Schools	
School:	Raton Intermediate School	
District/ Charter Contact Name	Kristie Medina	<i>District/Charter Signature:</i>
Fire Marshal/ PED Staff Name	Fire Chief Anthony Burk	<i>Fire Marshal/ PED Staff Signature</i>
Current Status Use Drop Down	Safe Practice	Notes/ Checklist
Yes	Multi-ply cloth masks available and utilized by all staff and students, over the nose and mouth, secure under the chin, snug on face with no gaps.	Extra disposable masks on hand? Yes adult and children
Yes	Classrooms and commons areas are set up for 6 feet social distancing with 50% student enrollment in place.	Are desk marked for A/B cohorts? Yes - desks are marked A/B cohorts Are desks/ students facing one direction? Yes - desks/students facing one direction.
Yes	If applicable, cafeteria (or other congregate feeding area) is set up for 6 feet social distancing and cohorts of students are not mixed.	Lunch is eaten in classrooms only.
Yes	Hand sanitizer that contains at least 60% alcohol is available across the school and ample cleaning supplies in place. Soap and supplies in bathrooms are ample with reliable running water.	
Yes	Sanitization protocols in place that address daily cleaning and disinfection with particular attention to frequently touched surfaces including both building, playground and buses.	Sanitization logs accesible and posted across the school site? See picture attached for sanitization log per door/room. Play ground not in use.
No	School doors and windows are operable and <u>other air filtration measures in place.</u>	Air purifiers in place - Medify Air model MA-112. 27 classrooms, 1 office, 1 nurse room, 1-gym, 1-caferteria, 1 principal office.
Yes	School ventilation systems are functional and meet standard.	HEPA Filters; Medify Air has 2 True HEPA H13 filters per unit. See attached picture.
Yes	Evacuation plan in place that maintains 6 feet social distancing. Dismissal process in place that maintains social distancing.	Pickmykid app is used and is in place.
Yes	Isolation rooms for symptomatic individuals in place and protocols for students exhibiting symptoms on buses in place.	Isolation room is in place and with PPE.
Yes	Protocols and signage in place for entrance into the building including temperature other symptoms check.	Protocols/signage found and used at North and East entry points.
Yes	Signage across the school site that includes expectations for prevention practices: frequently washing hands, avoiding touching eyes, nose, and mouth, wearing masks, staying 6 feet apart and direction of traffic.	Signage in multiple languages as appropriate? English and Spanish.
	General Notes - Still have issue/concern with fresh air intake to allow for proper air exchange as per Air Quality Diagram dated 10/15/20.	

